

**WAC 51-54A-3304 Protection of combustible materials.**

**3304.1 Combustible debris, rubbish, and waste.** Combustible debris, rubbish, and waste material shall comply with the requirements of Sections 3304.1.1 through 3304.2.

**3304.1.1 Combustible waste material accumulation.** Combustible debris, rubbish, and waste material shall not be accumulated within *buildings*.

**3304.1.2 Combustible waste material removal.** Combustible debris, rubbish, and waste material shall be removed from *buildings* at the end of each shift of work.

**3304.1.3 Rubbish containers.** Where rubbish containers with a capacity exceeding 5.33 cubic feet (40 gallons) (0.15 m) are used for temporary storage of combustible debris, rubbish, and waste material, they shall have tight-fitting or self-closing lids. Such rubbish containers shall be constructed entirely of materials that comply with either of the following:

1. Noncombustible materials.
2. Materials that meet a peak rate of heat release not exceeding 300 kW/m when tested in accordance with ASTM E1354 at an incident heat flux of 50 kW/m in the horizontal orientation.

**3304.2 Spontaneous ignition.** Materials susceptible to spontaneous ignition, such as oily rags, shall be stored in a listed disposal container.

[Statutory Authority: RCW 19.27.031 and 19.27.074. WSR 23-23-106, § 51-54A-3304, filed 11/15/23, effective 3/16/24; WSR 22-13-093, 23-12-107, and 23-20-027, § 51-54A-3304, filed 6/14/22, 6/7/23, and 9/25/23, effective 3/15/24; WSR 19-24-058, § 51-54A-3304, filed 11/27/19, effective 7/1/20.]