

WAC 212-12-035 Special requirements. In addition to the fire and life safety standards listed in WAC 212-12-010, the following shall apply: In all occupancies inspected by the state fire marshal's office, emergency lighting for means of egress shall be provided. Emergency systems shall activate automatically in a power failure and be supplied from storage batteries or an on-site generator set.

[Statutory Authority: RCW 18.20.130, 18.46.110, 18.51.140, 43.43.939, 70.41.080, 70.97.210, 71.12.485, 74.15.050 and chapter 43.44 RCW. WSR 20-20-062, § 212-12-035, filed 10/1/20, effective 11/1/20. Statutory Authority: Chapter 19.27 RCW. WSR 02-16-023, § 212-12-035, filed 7/29/02, effective 8/29/02. Statutory Authority: Chapters 43.63A and 48.48 RCW. WSR 93-05-032 (Order 93-02), § 212-12-035, filed 2/16/93, effective 3/19/93.]