

WAC 212-17-21511 Signs around the CFRS facility. (1) The minimum areas around the CFRS facility specified in WAC 212-17-21509 will be kept free of accumulation of dry grass, dry brush and combustible debris. No parking will be permitted within this minimum area.

(2) No motor vehicle or trailer may be parked within twenty feet of a CFRS facility except when delivering, loading or unloading fireworks.

(3) Fireworks will not be discharged within three hundred feet of a CFRS facility. Signs reading "NO FIREWORKS DISCHARGE WITHIN 300 FEET" will be in letters at least two inches high, with a principal stroke of not less than one-half inch, on contrasting background, will be conspicuously posted on all four sides of the stand.

(4) No smoking will be allowed within the CFRS facility or within the minimum flagged off area. Signs reading "NO SMOKING WITHIN 25 FEET" will be in letters at least two inches high, with principal stroke of not less than one-half inch, on a contrasting background, will be conspicuously posted on all four sides of the stand.

(5) Penalties for violations of this section are provided in WAC 212-17-515.

[Statutory Authority: RCW 70.77.250. WSR 15-22-082, § 212-17-21511, filed 11/3/15, effective 1/1/16. Statutory Authority: Chapters 43.43 and 70.77 RCW. WSR 05-12-033, § 212-17-21511, filed 5/24/05, effective 6/24/05. Statutory Authority: RCW 70.77.250 and chapters 70.77 and 43.43 RCW. WSR 98-04-007, § 212-17-21511, filed 1/23/98, effective 2/23/98.]