

**WAC 246-236-027 Fire protection.** (1) The radiation room at a panoramic or beam-type irradiator must have heat and smoke detectors. The detectors must activate an audible alarm. The alarm must be capable of alerting a person who is prepared to summon assistance promptly. The sources must automatically become fully shielded if a fire is detected.

(2) The radiation room at a panoramic or beam-type irradiator must be equipped with a fire extinguishing system capable of extinguishing a fire without the entry of personnel into the room. The system for the radiation room must have a shut-off valve to control flooding into unrestricted areas.

[Statutory Authority: RCW 70.98.050, 70.98.110 and 58 F.R. 7728, 76 F.R. 56963, 77 F.R. 39906, 80 F.R. 54234. WSR 18-15-017, § 246-236-027, filed 7/9/18, effective 8/9/18.]