

WAC 388-97-4120 Spouts in new construction. The nursing home must ensure all lavatories and sinks in resident rooms, resident toilet rooms, and utility and medication areas have gooseneck spouts, without aerators in areas requiring infection control.

[Statutory Authority: Chapters 18.51 and 74.42 RCW and 42 C.F.R. 489.52. WSR 08-20-062, § 388-97-4120, filed 9/24/08, effective 11/1/08.]