

**WAC 468-240-050 Marking overhead lines.** Overhead lines and cables required to be marked under the provisions of RCW 14.04.340 - 14.04.360, shall be marked by placing a marker as described in WAC 12-24-035(2) at least every 150 feet on, or within 30 feet of such lines or cables. See "marking of lines and cables or similar obstructions" (WAC 12-24-380(12)).

Such markers shall be colored international orange equivalent to federal specifications TT-P-59 or TT-E-489.

[Statutory Authority: Chapter 47.68 RCW. WSR 96-17-018 (Order 164), recodified as § 468-240-050, filed 8/13/96, effective 9/13/96; O.M.&L. standards (part), filed 9/13/61.]