



RULE-MAKING ORDER

CR-103 (June 2004) (Implements RCW 34.05.360)

Agency: State Building Code Council

- Permanent Rule
- Emergency Rule

Effective date of rule:

Permanent Rules

- 31 days after filing.
- Other (specify) July 1, 2007 (If less than 31 days after filing, a specific finding under RCW 34.05.380(3) is required and should be stated below)

Effective date of rule:

Emergency Rules

- Immediately upon filing.
- Later (specify) _____

Any other findings required by other provisions of law as precondition to adoption or effectiveness of rule?

- Yes
 - No
- If Yes, explain:

Purpose: To adopt and amend the 2006 Edition of the Uniform Plumbing Code Appendices, WAC 51-57

Citation of existing rules affected by this order:

Repealed:
Amended: 6
Suspended:

Statutory authority for adoption: RCW 19.27.190 and RCW 19.27.020

Other authority: RCW 19.27 and RCW 34.05

PERMANENT RULE ONLY (Including Expedited Rule Making)

Adopted under notice filed as WSR 06-16-111 on August 1, 2006 (date).
Describe any changes other than editing from proposed to adopted version: No changes were made.

If a preliminary cost-benefit analysis was prepared under RCW 34.05.328, a final cost-benefit analysis is available by contacting: N/A

Name: _____ phone () _____
Address: _____ fax () _____
e-mail _____

EMERGENCY RULE ONLY

Under RCW 34.05.350 the agency for good cause finds:

- That immediate adoption, amendment, or repeal of a rule is necessary for the preservation of the public health, safety, or general welfare, and that observing the time requirements of notice and opportunity to comment upon adoption of a permanent rule would be contrary to the public interest.
- That state or federal law or federal rule or a federal deadline for state receipt of federal funds requires immediate adoption of a rule.

Reasons for this finding:

Date adopted: November 17, 2006

NAME (TYPE OR PRINT)
John Neff

SIGNATURE
John Neff

TITLE
Council Chair

CODE REVISER USE ONLY

Stamp area containing:
 JUN 11 2007
 1059
 07-03-043
 (Circular stamp)

**Note: If any category is left blank, it will be calculated as zero.
No descriptive text.**

Count by whole WAC sections only, from the WAC number through the history note.
A section may be counted in more than one category.

The number of sections adopted in order to comply with:

Federal statute:	New	_____	Amended	_____	Repealed	_____
Federal rules or standards:	New	_____	Amended	_____	Repealed	_____
Recently enacted state statutes:	New	_____	Amended	_____	Repealed	_____

The number of sections adopted at the request of a nongovernmental entity:

New	Amended	Repealed	_____
-----	---------	----------	-------

The number of sections adopted in the agency's own initiative:

New	<u>1</u>	Amended	<u>6</u>	Repealed	_____
-----	----------	---------	----------	----------	-------

The number of sections adopted in order to clarify, streamline, or reform agency procedures:

New	_____	Amended	_____	Repealed	_____
-----	-------	---------	-------	----------	-------

The number of sections adopted using:

Negotiated rule making:	New	_____	Amended	_____	Repealed	_____
Pilot rule making:	New	_____	Amended	_____	Repealed	_____
Other alternative rule making:	New	<u>1</u>	Amended	<u>6</u>	Repealed	_____

AMENDATORY SECTION (Amending WSR 04-01-110, filed 12/17/03, effective 7/1/04)

WAC 51-57-003 Uniform Plumbing Code Standards. The ((2003)) 2006 edition of the Uniform Plumbing Code Standards (Appendixes A, B and I), published by the International Association of Plumbing and Mechanical Officials are hereby adopted by reference.

NEW SECTION

WAC 51-57-004 Conflicts between Appendix I and the manufacturer's installation instructions. Where a conflict exists between the provisions of Appendix I and the manufacturer's installation instructions, the conditions of the listing and the manufacturer's installation instructions shall apply.

AMENDATORY SECTION (Amending WSR 02-01-114, filed 12/18/01, effective 7/1/02)

WAC 51-57-007 Exceptions. The exceptions and amendments to the ((Uniform)) Model Codes contained in the provisions of chapter 19.27 RCW shall apply in cases of conflict with any of the provisions of these rules.

AMENDATORY SECTION (Amending WSR 04-01-110, filed 12/17/03, effective 7/1/04)

WAC 51-57-008 Implementation. The Uniform Plumbing Code Standards adopted by chapter 19.27 RCW shall become effective in all counties and cities of this state on July 1, ((2004)) 2007, unless local government residential amendments have been approved by the state building code council.

AMENDATORY SECTION (Amending WSR 04-01-110, filed 12/17/03, effective 7/1/04)

WAC 51-57-202000 Installation standard 20-200--CPVC solvent cemented hot and cold water distribution systems.

~~((301.1.1 Materials. Materials shall comply with the following:~~

Materials	ASTM Std
Raw Material - CPVC 23447-B	D1784-95
IPS pipe	
Sch 40 (1/2 in., 3/4 in., and 1 in.)	F 441-89 ^{er}
Sch 80 (1/2 in. - 2 in.)	F 441-94
Tubing	
SDR 11 (1/2 in. - 2 in.)	D2846-93
Fittings	
Sch 40 (1/2 in., 3/4 in., and 1 in.)	F 438-93
Sch 80 (1/2 in. - 2 in.)	F 439-93a
Tube Fittings (1/2 in. - 2 in.)	D2846-93))

2.1.2 Primer. Listed primers shall be used that are compatible with the type of listed CPVC cement and pipe used. The primer shall be a true solvent for CPVC, containing no slow-drying ingredient. Cleaners shall not be allowed to be used as a substitute or equivalent for a listed primer.

EXCEPTION: Listed solvent cements that do not require the use of primer shall be permitted for use with CPVC pipe and fittings, manufactured in accordance with ASTM D2845 ~~((1/2 in. - 2 in.)),~~ 1/2 inch through 2 inches in diameter.

AMENDATORY SECTION (Amending WSR 02-01-114, filed 12/18/01, effective 7/1/02)

WAC 51-57-790000 Installation Standard ~~((7-90))~~ 7-03-- Polyethylene cold water building supply and yard piping.

~~((604.1))~~ **2.6.1 Location.** Polyethylene piping may terminate within a building or structure. The connection to the potable water distribution system shall be accessible, except that it may be buried underground outside of the building or structure in an accessible location. Barbed insert fittings with hose clamps are prohibited within a building.

WAC 51-57-895000 Installation Standard ((8-95)) 8-03--PVC
cold water building supply and yard piping.

((604.1)) 2.7.1 Location. PVC piping may terminate within a
building or structure. The connection to the potable water
distribution system shall be accessible, except that it may be
buried underground outside of the building or structure in an
accessible location.