

JOHN SPELLMAN  
Governor



KARIN RAHM  
Director

STATE OF WASHINGTON

PLANNING & COMMUNITY AFFAIRS AGENCY

Ninth & Columbia Building MS/GH51 • Olympia, Washington 98504 • (206) 753-3200

December 13, 1983

Office of the Code Revisor  
Legislative Building  
Mail Stop AS-11  
Olympia, Washington 98504

Re: Correction of Amendments to WAC-51-12

Dear Sir:

The State Building Code Advisory Council has instructed me to make an editorial correction to Section 422 pipe insulation by adding the word "For" after the word surface on line 4 of the amendment. Section 422 is on page 5 of the amendment. The corrected Section will read as follows:

E. B. A pool at the surface of the water.

Section 422. Pipe Insulation. ~~For recirculation systems, the minimum piping insulation shall be in accordance with Table 4-17. For recirculating systems, piping heat loss shall be limited to a maximum of 25 BTU/hr.ft. of external pipe surface (for) above ground piping and a maximum of 35 BTU/hr.ft. of external surface for underground piping. Maximum heat loss shall be determined at a temperature differential equal to the maximum water temperature minus a design ambient temperature no higher than 65 degrees F.~~

Sincerely,

*Bert Baron*  
Bert Baron  
Council Staff

BB:mh

CC: Linda Steirmann  
Energy Office