

(Effective until July 1, 2020)

WAC 51-50-0422 Section 422—Ambulatory care facilities.

422.3.1 Means of egress. Where ambulatory care facilities require smoke compartmentation in accordance with Section 422.3, the fire safety evacuation plans provided in accordance with Section 1001.4 shall identify the building components necessary to support a staged evacuation emergency response in accordance with Sections 403 and 404 of the *International Fire Code*.

[Statutory Authority: RCW 19.27.031 and 19.27.074. WSR 16-03-064, § 51-50-0422, filed 1/19/16, effective 7/1/16. Statutory Authority: RCW 19.27.031 and chapters 19.27 and 34.05 RCW. WSR 13-04-067, § 51-50-0422, filed 2/1/13, effective 7/1/13. Statutory Authority: RCW 19.27.031 and 19.27.074. WSR 10-03-097, § 51-50-0422, filed 1/20/10, effective 7/1/10.]

(Effective July 1, 2020)

WAC 51-50-0422 Section 422—Ambulatory care facilities.

422.3.1 Means of egress. Where ambulatory care facilities require smoke compartmentation in accordance with Section 422.3, the fire safety evacuation plans provided in accordance with Section 1002.2 shall identify the building components necessary to support Sections 403 and 404 of the *International Fire Code*.

[Statutory Authority: RCW 19.27.031 and 19.27.074. WSR 20-01-090, § 51-50-0422, filed 12/12/19, effective 7/1/20; WSR 16-03-064, § 51-50-0422, filed 1/19/16, effective 7/1/16. Statutory Authority: RCW 19.27.031 and chapters 19.27 and 34.05 RCW. WSR 13-04-067, § 51-50-0422, filed 2/1/13, effective 7/1/13. Statutory Authority: RCW 19.27.031 and 19.27.074. WSR 10-03-097, § 51-50-0422, filed 1/20/10, effective 7/1/10.]