

(Effective July 1, 2020)

WAC 51-50-11090 Section 1109—Other features and facilities.

1109.2 Toilet and bathing facilities. Each toilet room and bathing room shall be accessible. Where a floor level is not required to be connected by an accessible route, the only toilet rooms or bathing rooms provided within the facility shall not be located on the inaccessible floor. Except as provided for in Sections 1109.2.3, 1109.2.4 and 1109.2.5 at least one of each type of fixture, element, control or dispenser in each accessible toilet room and bathing room shall be accessible.

EXCEPTIONS:

1. Toilet rooms or bathing rooms accessed only through a private office, not for common or public use and intended for use by a single occupant, shall be permitted to comply with the specific exceptions in ICC A117.1.
2. This section is not applicable to toilet and bathing rooms that serve dwelling units or sleeping units that are not required to be accessible by Section 1107.
3. Where multiple single-user toilet rooms or bathing rooms are clustered at a single location, at least 50 percent but not less than one room for each use at each cluster shall be accessible. Where these rooms are designated as gender-neutral, the total number of accessible toilet or bathing rooms shall not be less than the sum of required accessible separate male plus female rooms.
4. Where no more than one urinal is provided in a toilet room or bathing room, the urinal is not required to be accessible.
5. Toilet rooms or bathing rooms that are part of critical care or intensive care patient sleeping rooms serving accessible units are not required to be accessible.
6. Toilet rooms or bathing rooms designed for bariatrics patients are not required to comply with the toilet room and bathing room requirement in ICC A117.1. The sleeping units served by bariatrics toilet or bathing rooms shall not count toward the required number of accessible sleeping units.
7. Where permitted in Section 1107, in toilet rooms or bathrooms serving accessible units, water closets designed for assisted toileting shall comply with Section 1109.2.2.
8. Where permitted in Section 1107, in bathrooms serving accessible units, showers designed for assisted toileting shall comply with Section 1109.2.3.
9. Where toilet facilities are primarily for children's use, required accessible water closets, toilet compartments and lavatories shall be permitted to comply with children's provision of ICC A117.1.

1109.2.2 Water closets designed for assisted toileting. Water closets designed for assisted toileting shall comply with Sections 1109.2.2.1 through 1109.2.2.6.

1109.2.2.1 Location. The centerline of the water closet shall be 24 inches (610 mm) minimum and 26 inches (660 mm) maximum from one side of the required clearance.

1109.2.2.2 Clearance. Clearance around the water closet shall comply with Sections 1109.2.2.2.1 through 1109.2.2.2.3.

1109.2.2.2.1 Clearance width. Clearance around a water closet shall be 66 inches (1675 mm) minimum in width, measured perpendicular from the side of the clearance that is 24 inches (610 mm) minimum and 26 inches (660 mm) maximum from the water closet centerline.

1109.2.2.2.2 Clearance depth. Clearance around the water closet shall be 78 inches (1980 mm) minimum in depth, measured perpendicular from the rear wall.

1109.2.2.2.3 Clearance overlap. The required clearance around the water closet shall be permitted overlaps in accordance with ICC A117.1 Section 604.3.3.

1109.2.2.3 Height. The height of the water closet seats shall comply with ICC A117.1 Section 604.4.

1109.2.2.4 Swing-up grab bars. The swing-up grab bars shall comply with ICC A117.1 Sections 609.2 and 609.8. Swing-up grab bars shall be provided on both sides of the water closet and shall comply with all of the following:

1. The centerline of the grab bar shall be 14 inches minimum to 16 inches (356 mm to 405 mm) maximum from the centerline of the water closet.

2. The length of the grab bar is 36 inches (915 mm) minimum in length, measured from the rear wall to the end of the grab bar.

3. The top of the grab bar in the down position is 30 inches (760 mm) minimum and 34 inches (865 mm) maximum above the floor.

1109.2.2.5 Flush controls. Flush controls shall comply with ICC A117.1 Section 604.6.

1109.2.2.6 Dispensers. Toilet paper dispensers shall be mounted on at least one of the swing-up grab bars and the outlet of the dispenser shall be located at 24 inches (610 mm) minimum to 36 inches (915 mm) maximum from the rear wall.

1109.2.3 Standard roll-in-type shower compartment designed for assisted bathing. Standard roll-in-type shower compartments designed for assisted bathing shall comply with Sections 1109.2.3.1 through 1109.2.3.8.

1109.2.3.1 Size. Standard roll-in-type shower compartments shall have a clear inside dimension of 60 inches (1525 mm) minimum in width and 30 inches (760 mm) minimum in depth, measured at the center point of opposing sides. An entry 60 inches (1525 mm) minimum in width shall be provided.

1109.2.3.2 Clearance. A clearance of 60 inches (1525 mm) minimum in length adjacent to the 60 inch (1525 mm) width of the open face of the shower compartment, and 30 inches (760 mm) minimum in depth, shall be provided.

EXCEPTIONS: 1. A lavatory complying with Section 606 shall be permitted at one end of the clearance.
2. Where the shower compartment exceeds minimum sizes, the clear floor space shall be placed adjacent to the grab bars and 30 inches minimum from the back wall.

1109.2.3.3 Grab bars. Grab bars shall comply with ICC A117.1 Section 609 and shall be provided in accordance with Sections 1109.2.3.3.1 and 1109.2.3.3.2. In standard roll-in-type shower compartments, grab bars shall be provided on three walls. Where multiple grab bars are used, required horizontal grab bars shall be installed at the same height above the floor. Grab bars can be separate bars or one continuous bar.

1109.2.3.3.1 Back-wall grab bar. The back-wall grab bar shall extend the length of the back wall and extend within 6 inches (150 mm) maximum from the two adjacent side walls.

EXCEPTION: The back wall grab bar shall not be required to exceed 48 inches (1220 mm) in length. The rear grab bar shall be located with one end within 6 inches maximum of a side wall with a grab bar complying with Section 1109.2.3.3.2.

1109.2.3.3.2 Side-wall grab bars. The side-wall grab bars shall extend the length of the wall and extend within 6 inches (150 mm) maximum from the adjacent back wall.

EXCEPTIONS: 1. The side-wall grab bar shall not be required to exceed 30 inches (760 mm) in length. The side grab bar shall be located with one end within 6 inches maximum of the back wall with a grab bar complying with Section 1109.2.3.3.1.
2. Where the side walls are located 72 inches (1830 mm) or greater apart, a grab bar is not required on one of the side walls.

1109.2.3.4 Seats. Wall-mounted folding seats shall not be installed.

1109.2.3.5 Controls and hand showers. In standard roll-in-type showers, the controls and hand shower shall be located 38 inches (965 mm) minimum and 48 inches (1220 mm) maximum above the shower floor. Controls shall be located to facilitate caregiver access.

1109.2.3.6 Hand showers. Hand showers shall comply with ICC A117.1 Section 608.5.

1109.2.3.7 Thresholds. Thresholds shall comply with ICC A117.1 Section 608.6.

1109.2.3.8 Shower enclosures. Shower compartment enclosures for shower compartments shall comply with ICC A117.1 Section 608.7.

1109.2.3.9 Water temperature. Water temperature shall comply with ICC A117.1 Section 608.8.

1109.5.1 Minimum number. Not fewer than two drinking fountains shall be provided. One drinking fountain shall comply with the requirements for people who use a wheelchair and one drinking fountain shall comply with the requirements for standing persons.

- EXCEPTIONS:
1. A single drinking fountain with two separate spouts that complies with the requirements for people who use a wheelchair and standing persons shall be permitted to be substituted for two separate drinking fountains.
 2. Where drinking fountains are primarily for children's use, drinking fountains for people using wheelchairs shall be permitted to comply with the children's provisions in ICC A117.1 and drinking fountains for standing children shall be permitted to provide the spout at 30 inches (762 mm) minimum above the floor.
 3. In all occupancies that require more than two drinking fountains per floor or secured area, bottle filling stations shall be allowed to be substituted in accordance with Section 2902.5.

[Statutory Authority: RCW 19.27.031 and 19.27.074. WSR 20-01-090, § 51-50-11090, filed 12/12/19, effective 7/1/20.]