

(Effective until July 1, 2020)

WAC 51-54A-0909 Smoke control systems.

909.21.12 Hoistway venting. Hoistway venting required by Section 3009 of the state building code need not be provided for pressurized elevator shafts.

909.21.13 Machine rooms. Elevator machine rooms shall be pressurized in accordance with this section unless separated from the hoistway shaft by construction in accordance with Section 707 of the International Building Code.

[Statutory Authority: RCW 19.27.031 and 19.27.074. WSR 16-03-055, § 51-54A-0909, filed 1/16/16, effective 7/1/16. Statutory Authority: RCW 19.27A.031, 19.27.074 and chapters 19.27 and 34.05 RCW. WSR 13-04-063, § 51-54A-0909, filed 2/1/13, effective 7/1/13.]

(Effective July 1, 2020)

WAC 51-54A-0909 Smoke control systems.

909.6.3 Pressurized stairways and elevator hoistways. Where stairways or elevator hoistways are pressurized, such pressurization systems shall comply with the requirements of Section 909.20 of this code for stair pressurization and 909.21 of the *International Building Code and Fire Code* as necessary to determine that the stairway or elevator hoistways meet the pressurization requirements of the code. Stairway and elevator hoistway pressurization systems in high-rise buildings, underground buildings, and in airport traffic control towers shall comply with IBC and IFC Sections 909 as smoke control systems.

Stairway pressurization systems in other than high-rise buildings, underground buildings, or airport traffic control towers are smoke control systems but shall only be required to comply with the following IBC 909 Sections: 909.1, 909.2, 909.3, 909.6 with the exception of Section 909.6.1, 909.10 with the exception of Sections 909.10.2, 909.11 with the exception of Section 909.11.1, 909.12 with the exception of Sections 909.12.3.2, 909.13, 909.14, 909.17, 909.18 with the exception of Sections 909.18.2 and 909.18.9, 909.19, 909.20.5, and 909.20.6. Design drawings shall include a description of system operation, the conditions for system testing and the criteria for system acceptance to achieve the code minimum performance of the smoke control system. Stairway pressurization systems shall be maintained in accordance with Section 909.20 of this code.

Elevator hoistway pressurization systems in other than high-rise buildings, underground buildings, or airport traffic control towers are smoke control systems but shall only be required to comply with the following IBC 909 Sections: 909.1, 909.2, 909.3, 909.6 with the exception of Section 909.6.1, 909.10 with the exception of Sections 909.10.2, 909.11 with the exception of Section 909.11.1, 909.12 with the exception of Sections 909.12.3.2, 909.13, 909.14, 909.17, 909.18 with the exception of Sections 909.18.2 and 909.18.9, 909.19, and 909.21 with the exception of Sections 909.21.2, 909.21.9, and 909.21.10. Design drawings shall include a description of system operation, the conditions for system testing and the criteria for system acceptance to achieve the code minimum performance of the smoke con-

trol system. Elevator hoistway pressurization systems shall be maintained in accordance with Section 909.20 of this code.

909.21.12 Hoistway venting. Hoistway venting required by Section 3009 of the state building code need not be provided for pressurized elevator shafts.

909.21.13 Machine rooms. Elevator machine rooms shall be pressurized in accordance with this section unless separated from the hoistway shaft by construction in accordance with Section 707 of the *International Building Code*.

[Statutory Authority: RCW 19.27.031 and 19.27.074. WSR 20-01-162, § 51-54A-0909, filed 12/18/19, effective 7/1/20; WSR 16-03-055, § 51-54A-0909, filed 1/16/16, effective 7/1/16. Statutory Authority: RCW 19.27A.031, 19.27.074 and chapters 19.27 and 34.05 RCW. WSR 13-04-063, § 51-54A-0909, filed 2/1/13, effective 7/1/13.]