

WAC 173-130A-170 Casing and sealing. In order to protect existing shallow domestic and stock water wells, and springs, casing and sealing requirements will be determined on a case-by-case basis and included as a provision on all new permits issued. New permits will also be conditioned to prohibit cascading water in wells in accordance with chapter 173-160 WAC (Minimum standards for construction and maintenance of water wells). Sealing of required casing shall consist of filling the annular space between casing and well bore with cement grout placed by pumping from the bottom of the casing to land surface. Alternative methods to provide the same protection afforded by casing and sealing may be submitted to the department for review and shall only be used if approved in writing by the department prior to well completion.

[Statutory Authority: RCW 43.21A.060, 43.21A.080, 43.27A.090, 90.44.130 and 90.54.040(2). WSR 82-16-103 (Order DE 82-27), § 173-130A-170, filed 8/4/82.]