

WAC 296-96-02470 Fireman's service for groups of four or more.

Groups of elevators containing four or more cars may be provided with two three-position key switches per group. For purposes of this section, a group shall be defined as all elevators serving the same portion of a building. Hall call buttons common to a group will remain in service unless both Phase I recall switches of a four car or larger group are placed in the recall mode or a fire alarm recall signal is initiated.

[Statutory Authority: Chapter 70.87 RCW. WSR 18-18-070, § 296-96-02470, filed 8/31/18, effective 10/1/18; WSR 07-24-041, § 296-96-02470, filed 11/30/07, effective 1/1/08.]