

**WAC 296-96-18030 Electrical wiring requirements.** (1) All electric wiring used in boat launching elevators, except the traveling cable, shall be enclosed in rigid metal conduit.

(2) The traveling cable, which is required between the car mounted terminal stopping switch and the hoistway, shall be made of flexible, nonmetallic, moisture-retardant, flame-retardant material.

(3) All electrical outlets, switches, junction boxes and fittings used in boat launching elevators shall be weatherproof.

[Statutory Authority: Chapter 70.87 RCW. WSR 18-18-070, § 296-96-18030, filed 8/31/18, effective 10/1/18. Statutory Authority: RCW 70.87.020, 70.87.030, 70.87.034, 70.87.120, 70.87.185 and chapter 70.87 RCW. WSR 01-02-026, § 296-96-18030, filed 12/22/00, effective 1/22/01.]