

**WAC 296-307-44025 What fire protection must be provided at LP-gas service stations?** Each service station must have at least one approved portable fire extinguisher with at least an 8-B, C, rating.

[WSR 97-09-013, recodified as § 296-307-44025, filed 4/7/97, effective 4/7/97. Statutory Authority: RCW 49.17.040, [49.17.]050 and [49.17.]060. WSR 96-22-048, § 296-306A-44025, filed 10/31/96, effective 12/1/96.]