

**WAC 388-97-4120 Spouts in new construction.** The nursing home must ensure all lavatories and sinks in resident rooms, resident toilet rooms, and utility and medication areas have gooseneck spouts, without aerators in areas requiring infection control.

[Statutory Authority: Chapters 18.51 and 74.42 RCW and 42 C.F.R. 489.52. WSR 08-20-062, § 388-97-4120, filed 9/24/08, effective 11/1/08.]