

**WAC 468-240-120 Operation of obstruction lighting.** (1) The operation of obstruction lighting installed on obstructions of an overall height greater than 150 feet above ground, or water if so situated, should be controlled by a light sensitive control device adjusted so that the lights will be turned on at a north sky light intensity level of about 35 foot-candles and turned off at a north sky light intensity level of about 58 foot-candles, or should be continuous.

(2) Under normal conditions, where no special means of controlling obstruction lighting has been recommended, either a light sensitive control device or an astronomic dial clock and time switch may be used to control the obstruction lighting in lieu of manual control.

[Statutory Authority: Chapter 47.68 RCW. WSR 96-17-018 (Order 164), recodified as § 468-240-120, filed 8/13/96, effective 9/13/96; O.M.&L. standards (part), filed 9/13/61.]