

(Effective until February 1, 2021)

WAC 51-11C-40603 Section C406.3—LPA option.

C406.3 Reduced lighting power. Interior lighting within the whole building, building addition or tenant space shall comply with Section C406.3.1 or Section C406.3.2. Dwelling units and sleeping units within the building shall comply with Section C406.3.3.

C406.3.1 Reduced lighting power Option 1. The total connected interior lighting power calculated in accordance with Section C405.4.1 shall be 90 percent or less of the lighting power values specified in Table C405.4.2(1) times the floor area for the building types, or 90 percent or less of the total interior lighting power allowance calculated in accordance with Section C405.4.2.

C406.3.2 Reduced lighting power Option 2. The total connected interior lighting power calculated in accordance with Section C405.4.1 shall be 80 percent or less of the lighting power values specified in Table C405.4.2(1) times the floor area of the building types, or 80 percent or less of the total interior lighting power allowance calculated in accordance with Section C405.4.2.

C406.3.3 Lamp fraction. No less than 95 percent permanently installed light fixtures in dwelling units and sleeping units shall be provided by lamps with a minimum efficacy of 65 lumens per watt.

[Statutory Authority: RCW 19.27A.020, 19.27A.025, 19.27A.160 and chapter 19.27 RCW. WSR 19-24-040, § 51-11C-40603, filed 11/26/19, effective 7/1/20. Statutory Authority: RCW 19.27A.025, 19.27A.160, and 19.27.074. WSR 16-03-072, § 51-11C-40603, filed 1/19/16, effective 7/1/16.]

(Effective February 1, 2021)

WAC 51-11C-40603 Section C406.3—LPA option.

C406.3 Reduced lighting power. Interior lighting within the whole building, building addition or tenant space shall comply with Section C406.3.1 or Section C406.3.2. Dwelling units and sleeping units within the building shall comply with Section C406.3.3.

C406.3.1 Reduced lighting power Option 1. The total connected interior lighting power calculated in accordance with Section C405.4.1 shall be 90 percent or less of the lighting power values specified in Table C405.4.2(1) times the floor area for the building types, or 90 percent or less of the total interior lighting power allowance calculated in accordance with Section C405.4.2.

C406.3.2 Reduced lighting power Option 2. The total connected interior lighting power calculated in accordance with Section C405.4.1 shall be 80 percent or less of the lighting power values specified in Table C405.4.2(1) times the floor area of the building types, or 80 percent or less of the total interior lighting power allowance calculated in accordance with Section C405.4.2.

C406.3.3 Lamp fraction. No less than 95 percent of the permanently installed light fixtures in dwelling units and sleeping units shall be provided by lamps with a minimum efficacy of 65 lumens per watt.

[Statutory Authority: RCW 19.27A.025, 19.27A.045 and chapter 19.27 RCW. WSR 20-21-080, § 51-11C-40603, filed 10/19/20, effective 2/1/21. Statutory Authority: RCW 19.27A.020, 19.27A.025, 19.27A.160 and chapter 19.27 RCW. WSR 19-24-040, § 51-11C-40603, filed 11/26/19, effective 7/1/20. Statutory Authority: RCW 19.27A.025, 19.27A.160, and 19.27.074. WSR 16-03-072, § 51-11C-40603, filed 1/19/16, effective 7/1/16.]