

**WAC 51-11R-50200 Section R502—Additions.**

**R502.1 General.** Additions to an existing building, building system or portion thereof shall conform to the provisions of this code as those provisions relate to new construction without requiring the unaltered portion of the existing building or building system to comply with this code. Additions shall not create an unsafe or hazardous condition or overload existing building systems. An addition shall be deemed to comply with this code where the addition alone complies, where the existing building and addition comply with this code as a single building, or where the building with the addition uses no more energy than the existing building. Additions shall be in accordance with Section R502.1.1 or R502.1.2.

**R502.1.1 Prescriptive compliance.** Additions shall comply with Sections R502.1.1.1 through R502.1.1.4.

**R502.1.1.1 Building envelope.** New building envelope assemblies that are part of the addition shall comply with Sections R402.1, R402.2, R402.3.1 through R402.3.5, and R402.4.

EXCEPTION: Where nonconditioned space is changed to conditioned space, the building envelope of the addition shall comply where the UA, as determined in Section R402.1.4, of the existing building and the addition, and any alterations that are part of the project, is less than or equal to UA generated for the existing building.

**R502.1.1.2 Heating and cooling systems.** New heating, cooling and duct systems that are part of the addition shall comply with Section R403.

EXCEPTION: The following need not comply with the testing requirements of Section R403.3.3:

1. Additions of less than 750 square feet.
2. Duct systems that are documented to have been previously sealed as confirmed through field verification and diagnostic testing in accordance with procedures in WSU RS-33.
3. Ducts with less than 40 linear feet in unconditioned spaces.
4. Existing duct systems constructed, insulated or sealed with asbestos.

**R502.1.1.3 Service hot water systems.** New service hot water systems that are part of the addition shall comply with Section R403.5.

**R502.1.1.4 Lighting.** New lighting systems that are part of the addition shall comply with Section 404.1.

**R502.1.2 Existing plus addition compliance (Simulated Performance Alternative).** Where nonconditioned space is changed to conditioned space the addition shall comply where the annual energy use of the addition and the existing building, and any alterations that are part of the project, is less than or equal to the annual energy use of the existing building when modeled in accordance with Section R405. The addition and any alterations that are part of the project shall comply with Section R405 in its entirety.

[Statutory Authority: RCW 19.27A.020, 19.27A.045, 19.27A.160 and chapter 19.27 RCW. WSR 20-01-047, § 51-11R-50200, filed 12/9/19, effective 7/1/20. Statutory Authority: RCW 19.27A.025, 19.27A.045, 19.27A.160, and 19.27.074. WSR 17-10-063, § 51-11R-50200, filed 5/2/17, effective 6/2/17. Statutory Authority: RCW 19.27A.020, 19.27A.045, 19.27A.160, and 19.27.074. WSR 16-02-127, § 51-11R-50200, filed 1/6/16, effective 7/1/16.]