

*(Effective until March 1, 2022.)*

**WAC 246-215-05275 Operation and maintenance—Prohibiting a cross connection (2009 FDA Food Code 5-205.12).** (1) A PERSON may not create a cross connection by connecting a pipe or conduit between the DRINKING WATER system and a nonDRINKING WATER system or a water system of unknown quality.

(2) The piping of a nonDRINKING WATER system must be durably identified so that it is readily distinguishable from piping that carries DRINKING WATER.

[Statutory Authority: RCW 43.20.050 and 43.20.145. WSR 13-03-109, § 246-215-05275, filed 1/17/13, effective 5/1/13.]

*(Effective March 1, 2022.)*

**WAC 246-215-05275 Operation and maintenance—Prohibiting a cross connection (FDA Food Code 5-205.12).** (1) A PERSON may not create a cross connection by connecting a pipe or conduit between the DRINKING WATER system and a nonDRINKING WATER system or a water system of unknown quality.

(2) The piping of a nonDRINKING WATER system must be durably identified so that it is readily distinguishable from piping that carries DRINKING WATER.

[Statutory Authority: RCW 43.20.050 and 43.20.145. WSR 21-01-122, § 246-215-05275, filed 12/15/20, effective 3/1/22; WSR 13-03-109, § 246-215-05275, filed 1/17/13, effective 5/1/13.]