

**WAC 296-826-60030 Nonrefrigerated containers.**

<b>You must meet the requirements ...</b>	<b>in this section:</b>
Nonrefrigerated containers	WAC 296-826-60030
Refrigerated tanks	WAC 296-826-60035
Welding	WAC 296-826-60040

You must make sure filling densities for nonrefrigerated containers are below or equal to the requirements in Table 15, Filling Densities.

Table 15  
Filling Densities

Containers	Aboveground Containers	Underground Containers
Uninsulated	56%	58%
Insulated	57%	—

**Note:** For uninsulated, aboveground containers, the 56% corresponds to:  
1. 82% by volume at -28°F.  
2. 85% by volume at 5°F.  
3. 87.5% by volume at 30°F.  
4. 90.6% by volume at 60°F.

[Statutory Authority: RCW 49.17.010, 49.17.040, 49.17.050. WSR 15-23-086, § 296-826-60030, filed 11/17/15, effective 12/18/15. Statutory Authority: RCW 49.17.010, 49.17.040, 49.17.050, 49.17.060. WSR 06-10-067, § 296-826-60030, filed 5/2/06, effective 9/1/06.]