

**WAC 51-54A-0308 Open flames.**

**308.1.4 Open-flame cooking devices.** This section is not adopted.

**308.1.7 Religious ceremonies.** Participants in religious ceremonies shall not be precluded from carrying hand-held candles. See RCW 19.27.031(3).

**308.1.7.1 Aisles and exits.** Candles shall be prohibited in areas where occupants stand, or in an aisle or exit.

EXCEPTION: Candles used in religious ceremonies.

**308.1.9 Decorative open flame tables.** Gas-fired portable or fixed open flame fire tables and fireplaces are required to be provided with fire *code official* approved design or protection devices to prevent occupants from using flame, and from flame being exposed to combustible material. A fire extinguisher shall be located within 75 feet of travel distance or a distance as approved by the fire *code official*. Where located indoors, the supply gas valve will be interlocked with building fire alarm and/or fire sprinklers, where provided.

[Statutory Authority: RCW 19.27.031 and 19.27.074. WSR 21-04-003, § 51-54A-0308, filed 1/20/21, effective 2/20/21; WSR 16-03-055, § 51-54A-0308, filed 1/16/16, effective 7/1/16. Statutory Authority: RCW 19.27A.031, 19.27.074 and chapters 19.27 and 34.05 RCW. WSR 13-04-063, § 51-54A-0308, filed 2/1/13, effective 7/1/13.]