

**WAC 173-173-120 What are the operation and maintenance requirements for meters on pressure systems?** (1) Meters shall be inspected and maintained as specified by the manufacturer.

(2) Meters shall be field or shop calibrated, as specified by the manufacturer. Meters also shall be field or shop calibrated and/or repaired if they are over or under registering. System diagnostics may substitute for physical calibration of nonmechanical meters.

[Statutory Authority: RCW 90.03.360, 90.44.050, [90.44.]250, [90.44.]450 and chapter 43.21A RCW. WSR 02-02-017 (Order 00-01), § 173-173-120, filed 12/21/01, effective 1/21/02.]