

WAC 296-150V-1110 Combustible limitations. (1) The exposed wall adjacent to the cooking range must be 50 flame-spread or less, such as 5/16 inch gypsum board or material having equivalent fire protective properties.

(2) All openings for pipes and vents in furnace and water heater spaces shall be tight-fitted or fire-stopped.

[Statutory Authority: Chapter 43.22 RCW. WSR 99-18-069, § 296-150V-1110, filed 8/31/99, effective 10/1/99.]