

WAC 296-307-45535 Prevention of static electricity sparks or arcs when adding liquids to a dip tank. The employer must make sure any portable container used to add liquid to the tank is:

- (1) Electrically bonded to the dip tank;
- (2) Positively grounded.

[Statutory Authority: RCW 49.17.010, 49.17.040, 49.17.050, and 49.17.060. WSR 20-21-091, § 296-307-45535, filed 10/20/20, effective 11/20/20; WSR 03-10-068, § 296-307-45535, filed 5/6/03, effective 8/1/03.]