

*(Effective July 1, 2023)*

**WAC 51-50-0918 Section 918—Emergency responder communication coverage enhancement.**

**918.1 General.** In-building *emergency responder communication enhancement system* shall be provided in all new buildings in accordance with Section 510 of the *International Fire Code*.

[Statutory Authority: RCW 19.27.031 and 19.27.074. WSR 22-13-094, § 51-50-0918, filed 6/14/22, effective 7/1/23.]