

*(Effective until July 1, 2023)*

**WAC 51-50-11050 Section 1105—Accessible entrances.**

**1105.1.8 Automatic doors.** In facilities with the occupancies and building occupant loads indicated in Table 1105.1.8, all public entrances that are required to be accessible shall have one door be either a full power-operated door or a low-energy power-operated door. Where the public entrance includes a vestibule, at least one door into and one door out of the vestibule shall meet the requirements of this section.

**Table 1105.1.8<sup>a</sup>**

**PUBLIC ENTRANCE WITH POWER-OPERATED DOORS<sup>a</sup>**

<b>Occupancy</b>	<b>Building Occupant Load Greater Than</b>
A-1, A-2, A-3, A-4	300
B, M, R-1	500

<sup>a</sup> In mixed-use facilities containing occupancies listed, when the total sum of the occupant load is greater than those listed, the most restrictive building occupant load shall apply.

[Statutory Authority: RCW 19.27.031 and 19.27.074. WSR 20-01-090, § 51-50-11050, filed 12/12/19, effective 7/1/20.]

*(Effective July 1, 2023)*

**WAC 51-50-11050 Reserved.**

[Statutory Authority: RCW 19.27.031 and 19.27.074. WSR 22-13-094, § 51-50-11050, filed 6/14/22, effective 7/1/23; WSR 20-01-090, § 51-50-11050, filed 12/12/19, effective 7/1/20.]