

*(Effective July 1, 2023)*

**WAC 51-50-3314 Section 3314—Fire watch during construction.**

**3314.1 Fire watch during construction.** Where required by the fire code official, a fire watch shall be provided during nonworking hours for new construction that exceeds 40 feet (12,192 mm) in height above the lowest adjacent grade.

EXCEPTIONS:     1. New construction that is built under the IRC.  
                  2. New construction less than 5 stories and 50,000 square feet per story.

[Statutory Authority: RCW 19.27.031 and 19.27.074. WSR 22-13-094, § 51-50-3314, filed 6/14/22, effective 7/1/23.]