

**WAC 51-51-2101 Section M2101—Hydronic piping systems installation.**

**M2101.3 Protection of potable water.** The potable water system shall be protected from backflow in accordance with the provisions listed in Section 603 of the state plumbing code.

**M2101.7 Prohibited tee applications.** This section is not adopted.

[Statutory Authority: RCW 19.27.031 and 19.27.074. WSR 16-03-025, § 51-51-2101, filed 1/11/16, effective 7/1/16.]