

**(Effective until July 1, 2023)**

**WAC 51-54A-0605 Reserved.**

[Statutory Authority: RCW 19.27.031 and 19.27.074. WSR 20-01-162, § 51-54A-0605, filed 12/18/19, effective 7/1/20. Statutory Authority: RCW 19.27.031, 19.27.074 and chapters 19.27 and 34.05 RCW. WSR 17-18-060, § 51-54A-0605, filed 9/1/17, effective 10/2/17. Statutory Authority: Chapter 19.27 RCW and RCW 19.27.031. WSR 17-10-028, § 51-54A-0605, filed 4/25/17, effective 5/26/17. Statutory Authority: RCW 19.27.031 and 19.27.074. WSR 16-03-055, § 51-54A-0605, filed 1/16/16, effective 7/1/16. Statutory Authority: Chapters 19.27A and 34.05 RCW. WSR 13-24-076, § 51-54A-0605, filed 12/2/13, effective 4/1/14. Statutory Authority: RCW 19.27A.031, 19.27.074 and chapters 19.27 and 34.05 RCW. WSR 13-04-063, § 51-54A-0605, filed 2/1/13, effective 7/1/13.]

**(Effective July 1, 2023)**

**WAC 51-54A-0605 Fuel fired appliances.**

**605.4.1.1 Approval.** Outdoor fuel oil storage tanks shall be in accordance with UL 142, UL 142A, or UL 2085.

**605.4.2.1 Approval.** Indoor fuel oil storage tanks shall be in accordance with UL 80, UL 142, UL 142A, or UL 2085.

**605.4.2.2 Quantity limits.** One or more fuel oil storage tanks containing Class II or III combustible liquid shall be permitted in a building. The aggregate capacity of all tanks shall not exceed the following:

1. 660 gallons (2,498 L) in unsprinklered buildings, where stored in a tank complying with UL 80, UL 142, UL 142A, or UL 2085.

2. 1,320 gallons (4,996 L) in buildings equipped with an automatic sprinkler system in accordance with Section 903.3.1.1, where stored in a tank complying with UL 142 or UL 142A. The tank shall be listed as a secondary containment tank, and the secondary containment shall be monitored visually or automatically.

3. 3,000 gallons (11,356 L) in buildings equipped with an automatic sprinkler system in accordance with Section 903.3.1.1, where stored in protected above-ground tanks complying with UL 2085 and Section 5704.2.9.7. The tank shall be listed as a secondary containment tank, as required by UL 2085, and the secondary containment shall be monitored visually or automatically.

[Statutory Authority: RCW 19.27.031 and 19.27.074. WSR 22-13-093, § 51-54A-0605, filed 6/14/22, effective 7/1/23; WSR 20-01-162, § 51-54A-0605, filed 12/18/19, effective 7/1/20. Statutory Authority: RCW 19.27.031, 19.27.074 and chapters 19.27 and 34.05 RCW. WSR 17-18-060, § 51-54A-0605, filed 9/1/17, effective 10/2/17. Statutory Authority: Chapter 19.27 RCW and RCW 19.27.031. WSR 17-10-028, § 51-54A-0605, filed 4/25/17, effective 5/26/17. Statutory Authority: RCW 19.27.031 and 19.27.074. WSR 16-03-055, § 51-54A-0605, filed 1/16/16, effective 7/1/16. Statutory Authority: Chapters 19.27A and 34.05 RCW. WSR 13-24-076, § 51-54A-0605, filed 12/2/13, effective 4/1/14. Statutory Authority: RCW 19.27A.031, 19.27.074 and chapters

19.27 and 34.05 RCW. WSR 13-04-063, § 51-54A-0605, filed 2/1/13, effective 7/1/13.]