

(Effective July 1, 2023)

WAC 51-54A-0913 Section 913—Fire pumps.

913.2.1 Protection of fire pump rooms and access. Fire pumps shall be located in rooms that are separated from all other areas of the building by 2-hour fire barriers constructed in accordance with Section 707 of the *International Building Code* or 2-hour horizontal assemblies constructed in accordance with Section 711 of the *International Building Code*, or both. Fire pump rooms not directly accessible from the outside shall be accessible through an enclosed passageway from an interior exit stairway or exterior exit. The enclosed passageway shall have a *fire-resistance rating* not less than the *fire-resistance rating* of the fire pump room (see NFPA 20 Section 4.14.2.1.2).

[Statutory Authority: RCW 19.27.031 and 19.27.074. WSR 22-13-093, § 51-54A-0913, filed 6/14/22, effective 7/1/23.]