

WAC 388-847-0180 What water temperature safety measures must be met? (1) The stabilization, assessment, and intervention (SAIF) must regulate the facility's water temperature no higher than 120 degrees Fahrenheit.

(2) SAIF must complete and document monthly water temperature checks.

[Statutory Authority: RCW 71A.12.030 and 2019 c 415 § 203(j). WSR 22-11-056, § 388-847-0180, filed 5/16/22, effective 6/16/22.]