

(Effective until March 15, 2024)

WAC 51-50-1009 Section 1009—Accessible means of egress.

1009.1 Accessible means of egress required. Accessible means of egress shall comply with this section. Accessible spaces shall be provided with not less than one accessible means of egress. Where more than one means of egress is required by Section 1006.2 or 1006.3 from any accessible space, each accessible portion of the space shall be served by not less than two accessible means of egress.

EXCEPTIONS:

1. Accessible means of egress are not required to be provided in existing buildings.
2. One accessible means of egress is required from an accessible mezzanine level in accordance with Section 1009.3, 1009.4 or 1009.5.
3. In assembly areas with ramped aisles or stepped aisles, one accessible means of egress is permitted where the common path of egress travel is accessible and meets the requirements in Section 1029.8.
4. In parking garages, accessible means of egress are not required to serve parking areas that do not contain accessible parking spaces.

1009.2.1 Elevators required. In buildings where a required accessible floor or accessible occupied roof is four or more stories above or below a level of exit discharge, not less than one required accessible means of egress shall be an elevator complying with Section 1009.4.

EXCEPTIONS:

1. In buildings equipped throughout with an automatic sprinkler system installed in accordance with Section 903.3.1.1 or 903.3.1.2, the elevator shall not be required on floors provided with a horizontal exit and located at or above the levels of exit discharge.
2. In buildings equipped throughout with an automatic sprinkler system installed in accordance with Section 903.3.1.1 or 903.3.1.2, the elevator shall not be required on floors provided with a ramp conforming to the provisions of Section 1012.

1009.8 Two-way communication. A two-way communication system complying with Sections 1009.8.1 and 1009.8.2 shall be provided at the landing serving each elevator or bank of elevators on each accessible floor that is one or more stories above or below the level of exit discharge.

EXCEPTIONS:

1. Two-way communication systems are not required at the landing serving each elevator or bank of elevators where the two-way communication system is provided within areas of refuge in accordance with Section 1009.6.5.
2. Two-way communication systems are not required on floors provided with ramps that provide a direct path of egress travel to grade or the level of exit discharge conforming to the provisions of Section 1012.
3. Two-way communication systems are not required at the landings serving only service elevators that are not designated as part of the accessible means of egress or serve as part of the required accessible route into a facility.
4. Two-way communication systems are not required at the landings serving only freight elevators.
5. Two-way communication systems are not required at the landing serving a private residence elevator.
6. Two-way communication systems are not required in Group I-2 or I-3 facilities.

1009.8.1 System requirements. Two-way communication systems shall provide communication between each required location and the fire command center or a central control point location approved by the fire department. Where the central control point is not a constantly attended location, a two-way communication system shall have a timed automatic telephone dial-out capability to a monitoring location. The two-way communication system shall include both audible and visible signals. The two-way communication system shall have a battery backup or an approved alternate source of power that is capable of 90 minutes use upon failure of the normal power source.

[Statutory Authority: RCW 19.27.031 and 19.27.074. WSR 20-21-021, § 51-50-1009, filed 10/9/20, effective 11/9/20; WSR 20-01-090, § 51-50-1009, filed 12/12/19, effective 7/1/20; WSR 16-03-064, § 51-50-1009, filed 1/19/16, effective 7/1/16. Statutory Authority: RCW 19.27.031 and chapters 19.27 and 34.05 RCW. WSR 13-04-067, § 51-50-1009, filed 2/1/13, effective 7/1/13. Statutory Authority: RCW 19.27.031 and 19.27.074. WSR 10-03-097, § 51-50-1009, filed 1/20/10, effective 7/1/10. Statutory Authority: RCW 19.27.074, 19.27.020, and chapters 70.92, 19.27, and 34.05 RCW. WSR 07-01-091, § 51-50-1009, filed 12/19/06, effective 7/1/07. Statutory Authority: RCW 19.27.031 and 19.27.074. WSR 04-01-108, § 51-50-1009, filed 12/17/03, effective 7/1/04.]

(Effective March 15, 2024)

WAC 51-50-1009 Section 1009—Accessible means of egress.

1009.1 Accessible means of egress required. *Accessible means of egress* shall comply with this section. *Accessible* spaces shall be provided with not less than one *accessible means of egress*. Where more than one *means of egress* is required by Section 1006.2 or 1006.3 from any *accessible* space, each *accessible* portion of the space shall be served by not less than two *accessible means of egress*.

EXCEPTIONS:

1. *Accessible means of egress* are not required to be provided in existing buildings.
2. One *accessible means of egress* is required from an *accessible mezzanine* level in accordance with Section 1009.3, 1009.4 or 1009.5.
3. In assembly areas with ramped *aisles* or stepped *aisles*, one *accessible means of egress* is permitted where the *common path of egress travel* is *accessible* and meets the requirements in Section 1030.8.
4. In parking garages, *accessible means of egress* are not required to serve parking areas that do not contain *accessible parking spaces*.

1009.8 Two-way communication. A two-way communication system complying with Sections 1009.8.1 and 1009.8.2 shall be provided at the landing serving each elevator or bank of elevators on each *accessible* floor that is one or more stories above or below the *level of exit discharge*.

EXCEPTIONS:

1. Two-way communication systems are not required at the landing serving each elevator or bank of elevators where the two-way communication system is provided within *areas of refuge* in accordance with Section 1009.6.5.
2. Two-way communication systems are not required on floors provided with *ramps* that provide a direct path of egress travel to grade or the level of exit discharge conforming to the provisions of Section 1012.
3. Two-way communication systems are not required at the landings serving only service elevators that are not designated as part of the *accessible means of egress* or serve as part of the required *accessible route* into a facility.
4. Two-way communication systems are not required at the landings serving only freight elevators.
5. Two-way communication systems are not required at the landing serving a private residence elevator.
6. Two-way communication systems are not required in Group I-2 or I-3 facilities.

1009.8.1 System requirements. Two-way communication systems shall provide communication between each required location and the *fire command center* or a central control point location *approved* by the fire department. Where the central control point is not a *constantly attended location*, a two-way communication system shall have a timed automatic telephone dial-out capability that provides two-way communication with an *approved supervising station*. The two-way communication system shall include both audible and visible signals. The two-way communication system shall have a battery backup or an *approved alternate source of power* that is capable of 90 minutes use upon failure of the normal power source.

[Statutory Authority: RCW 19.27.031 and 19.27.074. WSR 22-13-094, 23-12-103, and 23-20-023, § 51-50-1009, filed 6/14/22, 6/7/23, and 9/25/23, effective 3/15/24; WSR 20-21-021, § 51-50-1009, filed 10/9/20, effective 11/9/20; WSR 20-01-090, § 51-50-1009, filed 12/12/19, effective 7/1/20; WSR 16-03-064, § 51-50-1009, filed 1/19/16, effective 7/1/16. Statutory Authority: RCW 19.27.031 and chapters 19.27 and 34.05 RCW. WSR 13-04-067, § 51-50-1009, filed 2/1/13, effective 7/1/13. Statutory Authority: RCW 19.27.031 and 19.27.074. WSR 10-03-097, § 51-50-1009, filed 1/20/10, effective 7/1/10. Statutory Authority: RCW 19.27.074, 19.27.020, and chapters 70.92, 19.27, and 34.05 RCW. WSR 07-01-091, § 51-50-1009, filed 12/19/06, effective 7/1/07. Statutory Authority: RCW 19.27.031 and 19.27.074. WSR 04-01-108, § 51-50-1009, filed 12/17/03, effective 7/1/04.]