

(Effective until March 15, 2024)

WAC 51-50-11050 Section 1105—Accessible entrances.

1105.1.8 Automatic doors. In facilities with the occupancies and building occupant loads indicated in Table 1105.1.8, all public entrances that are required to be accessible shall have one door be either a full power-operated door or a low-energy power-operated door. Where the public entrance includes a vestibule, at least one door into and one door out of the vestibule shall meet the requirements of this section.

Table 1105.1.8^a

PUBLIC ENTRANCE WITH POWER-OPERATED DOORS^a

Occupancy	Building Occupant Load Greater Than
A-1, A-2, A-3, A-4	300
B, M, R-1	500

^a In mixed-use facilities containing occupancies listed, when the total sum of the occupant load is greater than those listed, the most restrictive building occupant load shall apply.

[Statutory Authority: RCW 19.27.031 and 19.27.074. WSR 20-01-090, § 51-50-11050, filed 12/12/19, effective 7/1/20.]

(Effective March 15, 2024)

WAC 51-50-11050 Reserved.

[Statutory Authority: RCW 19.27.031 and 19.27.074. WSR 22-13-094, 23-12-103, and 23-20-023, § 51-50-11050, filed 6/14/22, 6/7/23, and 9/25/23, effective 3/15/24; WSR 20-01-090, § 51-50-11050, filed 12/12/19, effective 7/1/20.]