

***(Effective March 15, 2024)***

**WAC 51-50-2103 Section 2103—Mortar.**

**2103.2.4 Mortar for adhered masonry veneer.** Mortar for use with adhered masonry veneer shall conform to ASTM C270 for Type N or S, or shall comply with ANSI A118.4 or A118.15 for modified dry-set cement mortar. The cementitious bond coat shall comply with ANSI A118.4 or A118.15.

[Statutory Authority: RCW 19.27.031, 19.27.074, and 19.27.540. WSR 23-02-073, 23-12-103, and 23-20-023, § 51-50-2103, filed 1/4/23, 6/7/23, and 9/25/23, effective 3/15/24.]

***(Effective March 16, 2024)***

**WAC 51-50-2103 Section 2103—Masonry construction materials.**

**2103.2.4 Mortar for adhered masonry veneer.** Mortar for use with adhered masonry veneer shall conform to ASTM C270 for Type N or S, or shall comply with ANSI A118.4 or A118.15 for modified dry-set cement mortar. The cementitious bond coat shall comply with ANSI A118.4 or A118.15.

[Statutory Authority: RCW 19.27.031 and 19.27.074. WSR 23-23-102, § 51-50-2103, filed 11/15/23, effective 3/16/24. Statutory Authority: RCW 19.27.031, 19.27.074, and 19.27.540. WSR 23-02-073, 23-12-103, and 23-20-023, § 51-50-2103, filed 1/4/23, 6/7/23, and 9/25/23, effective 3/15/24.]