

(Effective March 15, 2024)

WAC 51-55-0400 Wildland-urban interface area requirements.

401 General.

401.1 Scope. *Wildland-urban interface areas* shall be provided with emergency vehicle access and water supply in accordance with this chapter.

401.2 Objective. This section is not adopted.

401.3 General safety precautions. This section is not adopted.

402 Applicability.

402.1 Subdivisions. Subdivisions shall comply with locally adopted standards.

402.1.1 Access. This section is not adopted.

402.1.2 Water supply. This section is not adopted.

402.2 Individual structures. Individual structures shall comply with Sections 402.2.1 and 402.2.2.

402.2.1 Access. Individual structures hereafter constructed or relocated into or within *wildland-urban interface areas* shall be provided with driveways in accordance with Section 403.2 and locally adopted standards. Marking of fire protection equipment shall be provided in accordance with Section 403.5 and address markers shall be provided in accordance with Section 403.6.

402.2.2 Water supply. Individual structures hereafter constructed or relocated into or within *wildland-urban interface areas* shall be provided with a conforming water supply in accordance with locally adopted standards.

EXCEPTION: Not adopted.

402.3 Existing conditions. This section is not adopted.

403 Access.

403.2.1 Dimensions. This section is not adopted.

403.2.2 Length. This section is not adopted.

403.2.3 Service limitations. This section is not adopted.

403.2.4 Turnarounds and turnouts. *Driveways* in excess of three hundred feet in length shall be provided with turnarounds. *Driveways* in excess of five hundred feet in length and less than twenty feet in width shall be provided with turnouts and turnarounds. Turnarounds and turnouts shall be designed as required by locally adopted standards.

403.2.5 Turnouts. This section is not adopted.

403.3 Fire apparatus access road. Where required, fire apparatus access roads shall be provided and maintained as required by locally adopted street, road, and access standards.

403.4 Marking of roads. This section is not adopted.

403.4.1 Sign construction. This section is not adopted.

404 Water supply.

404.1 General. Water supply shall be provided and maintained as required by locally adopted standards.

404.2 Water sources. This section is not adopted.

404.3 Draft sites. This section is not adopted.

404.3.1 Access. This section is not adopted.

404.3.2 Pumper access points. This section is not adopted.

404.4 Hydrants. This section is not adopted.

404.5 Adequate water supply. This section is not adopted.

404.6 Fire department. This section is not adopted.

404.7 Obstructions. This section is not adopted.

404.8 Identification. This section is not adopted.

404.9 Testing and maintenance. This section is not adopted.

404.10 Reliability. This section is not adopted.

404.10.1 Objective. This section is not adopted.

404.10.2 Clearance of fuel. This section is not adopted.

404.10.3 Standby power. This section is not adopted.

[Statutory Authority: RCW 19.27.031, 19.27.074, and 19.27.560. WSR 23-02-056, 23-12-109, and 23-20-028, § 51-55-0400, filed 1/3/23, 6/7/23, and 9/25/23, effective 3/15/24.]