

WAC 296-150C-1410 Gas piping—Electrical ground. (1) Gas piping must not be used for an electrical ground.
(2) The gas line must be bonded.

[Statutory Authority: RCW 43.22.340, [43.22.]355, [43.22.]360, [43.22.]432, [43.22.]440 and [43.22.]480. WSR 96-21-146, § 296-150C-1410, filed 10/23/96, effective 11/25/96.]