

WAC 51-50-0911 Section 911—Fire command center.

911.1.2 Separation. The *fire command center* shall be separated from the remainder of the building by not less than a one 2-hour fire barrier constructed in accordance with Section 707 or horizontal assembly constructed in accordance with Section 711, or both.

[Statutory Authority: RCW 19.27.031 and 19.27.074. WSR 22-13-094, 23-12-103, and 23-20-023, § 51-50-0911, filed 6/14/22, 6/7/23, and 9/25/23, effective 3/15/24; WSR 16-03-064, § 51-50-0911, filed 1/19/16, effective 7/1/16; WSR 10-03-097, § 51-50-0911, filed 1/20/10, effective 7/1/10.]