

WAC 296-96-23122 Machine room and machinery space illumination.

Elevators installed under the 1996 and earlier editions of ASME A17.1/CSA B44 shall have a minimum of 10 foot-candles of illumination at floor level within the working areas in machine rooms and machinery spaces.

[Statutory Authority: RCW 70.87.030. WSR 23-17-141, § 296-96-23122, filed 8/22/23, effective 10/2/23. Statutory Authority: Chapter 70.87 RCW. WSR 18-18-070, § 296-96-23122, filed 8/31/18, effective 10/1/18; WSR 07-24-041, § 296-96-23122, filed 11/30/07, effective 1/1/08. Statutory Authority: RCW 70.87.020, 70.87.030, 70.87.034, 70.87.120, 70.87.185 and chapter 70.87 RCW. WSR 01-02-026, § 296-96-23122, filed 12/22/00, effective 1/22/01.]