

**WAC 296-104-151 Inspection—What are the requirements for rental boilers?** Every rental boiler used in the state of Washington will have an internal inspection as defined in WAC 296-104-010 witnessed by an inspector once a year. An external inspection as defined in WAC 296-104-010 shall be witnessed by an inspector at each and every rental location before being placed into service. Rental boilers shall also meet the requirements of WAC 296-104-300.

A rental boiler, which has never been in rental service in the state of Washington, shall meet the requirements of WAC 296-104-273. Each inspection will be reported to the state of Washington in accordance with WAC 296-104-040, and a copy of this report will be posted on the rental boiler.

It is the responsibility of the rental boiler owner to arrange for all required inspections.

[Statutory Authority: RCW 70.79.030, 70.79.040, 70.79.150, 70.79.290, 70.79.330, 70.79.350, and chapter 70.79 RCW. WSR 02-23-036, § 296-104-151, filed 11/13/02, effective 12/14/02; WSR 01-24-061, § 296-104-151, filed 11/30/01, effective 12/31/01. Statutory Authority: RCW 70.79.030 and 70.79.040. WSR 99-22-026, § 296-104-151, filed 10/26/99, effective 11/26/99; WSR 96-21-081, § 296-104-151, filed 10/16/96, effective 11/16/96.]