

**WAC 296-104-325 Installation—What are the requirements for boiler and unfired pressure vessel supports?** Each boiler or unfired pressure vessel shall be supported by masonry or structural supports of sufficient strength and rigidity to safely support the vessel and its contents. There shall be no excessive vibration in either the vessel or its connecting piping.

[Statutory Authority: RCW 70.79.030, 70.79.040, 70.79.150, 70.79.290, 70.79.330, 70.79.350, and chapter 70.79 RCW. WSR 04-01-194, § 296-104-325, filed 12/24/03, effective 1/24/04. Statutory Authority: RCW 70.79.030 and 70.79.040. WSR 97-20-109, § 296-104-325, filed 9/30/97, effective 10/31/97; Part V, § 6, filed 3/23/60.]