

**WAC 388-829Z-050 How must the provider regulate the water temperature at Rainier School?** (1) The provider must regulate the water temperature at Rainier School as follows:

(a) Maintain the water temperature in the household between 105 degrees and 120 degrees Fahrenheit; and

(b) Check the water temperature at least once every six months.

(2) The provider must document compliance with these requirements.

[Statutory Authority: RCW 71A.12.030 and chapter 71A.20 RCW. WSR 23-13-087, § 388-829Z-050, filed 6/16/23, effective 7/17/23.]